

Permit # _____

Craven County Inspections Department
2824 Neuse Boulevard
New Bern, NC 28562
(252) 636-4987, Fax (252) 636-4984

www.cravencountync.gov



TEMPORARY/CONDITIONAL POWER APPLICATION

Date: _____ PERMIT FEE: \$ _____

Applicant's Name: _____ Phone #: _____

Address Power Requested For: _____

Duration of Temporary Power: _____ Days (180 days maximum)

PORTIONS OF PERMANENT WIRING SYSTEM TO BE ENERGIZED:

HVAC/WIRING Yes _____ No _____

Lighting Circuits Yes _____ No _____

*120-V Receptacle Circuits Yes _____ No _____

Other (Specify) _____

***Note:** All 120 V Receptacles Circuits to be energized **MUST** have GFCI Protection.

THE FOLLOWING STATEMENTS REQUIRE SIGNATURES BY CONTRACTORS:

1. The portions of the permanent wiring system stated above are suitable to be energized, and operated.
Electrical Contractor's Signature: _____
2. The mechanical equipment is suitable to be energized and operated:
Mechanical Contractor's Signature: _____
3. The plumbing equipment is suitable to be energized and operated (if applicable):
Plumbing Contractor's Signature: _____
4. The fire/life safety equipment is suitable to be energized and operated (if applicable):
Fire Contractor's Signature: _____
Fire Permit # _____
5. Upon receiving temporary power, _____, (Building Contractor), Will be responsible to supervise use of such power and will insure that all requirements of *Section 10.8 of the North Carolina State Electrical Code are **STRICTLY** adhered to. (*Copy Attached).

By signing below I agree that if the building is occupied prior to a certificate of occupancy being issued power may be removed
Responsible Agent Signature: _____

***** See Second Page for Additional Information*****

prior to taking such action. If not notified prior to disconnecting, the owner or occupant shall be notified in writing within eight (8) working hours (General Statutes 143-143.2, 153A-365, 153A-366, 160A-425 and 160A-426).

10.8 Temporary Power

10.8.1 Scope. The provisions of this section apply to the utilization of portions of the wiring system within a building to facilitate construction.

10.8.2 Provisions for Temporary Power. The Code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following requirements have been met:

- 1) The service wiring and equipment, including the meter socket enclosure, shall be installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized shall be complete and physically protected.
- 3) The grounding electrode system shall be complete.
- 4) The grounding and the grounded conductors shall be terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel shall be installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code apply.

10.8.3 Uses Prohibited. In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

10.8.4 Application for Temporary Power. Application for temporary power shall be made by and in the name of the applicant. The application shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, and its intended use and duration.

10.8.5 Security and Notification. The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. The applicant shall alert personnel working in the vicinity of the energized electrical system to its presence.

10.9 Requirements of Other State Agencies, Occupational Licensing Boards, or Commissions

The North Carolina State Building Codes do not include all additional requirements for buildings and structures that may be imposed by other State agencies, occupational licensing boards, and commissions. It shall be the responsibility of a permit holder, design professional, contractor, or occupational license holder to determine whether any additional requirements exist.